



# Sanitary Sewer Overflow 5-Day Follow Up Report

Division of Surface Water

## Report Submitted By

Date: 4/8/2016

Facility name: Gary L. Kron WRF

Ohio NPDES permit no.: 3PK00033\*MD

Period covered by report: 4/7/2016

## Contact person

Name: Michael McGlothlin

Title: Superintendent

Mailing address: 8471 Lakeshore Blvd. Mentor, Ohio 44060

County: Lake

Telephone: (440)350 - 3431

Email: Michael.mcglathin@lakecountyohio.gov

## Signature required at end of form

## Overflow Information

Event start date and time –  
if multiple locations, include  
information for each

4/7/2016 at 9:30am

Event end date and time

4/7/2016 at 11:00am

Location(s) the SSO –  
include unique ID number of  
one exists

Easement east of Water Street in Fairport Harbor, Ohio between manhole numbers 1375 and 1376.

Destination(s) of overflow

☐ Basement or building ☒ Ground ☐ Storm sewer to receiving water ☐ Directly to receiving water

Estimated volume (million  
gallons) - if multiple  
locations, include volume  
for each

0.035 MGD

Sewer system component(s)  
from which release occurred

☐ Manhole ☐ Constructed overflow ☐ Pipe crack ☐ Pump station  
☒ Other (explain) Released through sewer pipe joints.

Cause(s) of overflow

☐ Extreme weather ☐ Equipment failure ☐ Power failure  
☒ Debris in line ☐ Roots ☐ Grease  
☐ Other blockages ☐ Line deterioration ☐ Vandalism  
☐ Other (explain)